

Rep. Vose, Rock. 5
Rep. Mattson, Ches. 18
Rep. D. Thomas, Rock. 16
Rep. Schneller, Hills. 2
Rep. McGhee, Hills. 35
March 2, 2026
2026-0935h
04/09

Amendment to HB 1723

1 Amend the bill by replacing all after the enacting clause with the following:

2

3 1 Short title. This act shall be known as "Survey All Vulnerable Electric Transformers Act."

4 2 Findings.

5 I. America's electric grid is critical to modern life and faces existential threats from solar
6 weather events (coronal mass ejections—CME), geomagnetic disturbances—GMDs, and high-
7 altitude nuclear electromagnetic pulse—HEMP, all capable of disabling electric power systems.

8 II. High voltage transformers are especially vulnerable to geomagnetically induced
9 currents—GICs—whether induced by GMDs or HEMP E3 component, entering the grid through
10 ground-connected neutral wires.

11 III. Extra High Voltage (EHV) transformers (345 kV–765 kV) are most vulnerable and
12 difficult to replace, with production lead times of up to 4–6 years.

13 IV. GIC vulnerability is influenced by transformer characteristics, ground conductivity, and
14 the magnetic field intensity from GMD or E3 HEMP.

15 V. Aging transformers are more susceptible to GIC due to degraded insulating oil and coil
16 condition.

17 VI. Federal and international standards highlight the importance of transformer
18 assessment and protection against these threats.

19 VII. On July 23, 2012, a powerful CME erupted off the back side of the sun racing through
20 Earth's orbit missing Earth by 9 days. It was measured by STEREO-A satellite and determined by
21 the National Oceanic and Atmospheric Administration to be in all respects at least the size of the
22 Carrington event of 1859.

23 VIII. In 2012, the United States Department of Energy's Idaho National Laboratory working
24 with the United States Department of Defense's Defense Threat Reduction Agency conducted live
25 grid E3 HEMP tests to analyze GIC harmonic threats to the electric power grid. The results showed
26 transformer half-cycle saturation and generation of harmonics that exceeded the IEEE 519 Standard
27 with GIC of 15 Amps in the neutral of the power transformer.

Amendment to HB 1723

- Page 2 -

1 IX. In February 2013, the North American Electric Reliability Corporation (NERC) GMD
2 committee of 8 respected space weather scientists estimated a reference storm. Preliminary results
3 showed a peak electric field strength of 30 V/km to 40 V/km.

4 X. In May 2025, the International Electrotechnical Commission (IEC) updated the
5 international standard IEC 61000-2-9 for E3 HEMP to 85 V/km.

6 XI. The NERC GMD Standard requires New Hampshire to model roughly 3 V/km.

7 XII. With the existence of validated GIC mitigation hardware that protects power
8 transformers and improves grid resilience against these severe GIC events, reliance on load
9 shedding or operating procedures which cannot block GIC are no longer justified.

10 3 Geomagnetic and Electromagnetic Disturbance Electric Transmission; Department of Energy;
11 Vulnerability Investigation.

12 I. The department of energy shall investigate the vulnerability of electric transmission
13 transformers and other system components to geomagnetically induced currents. The investigation
14 shall answer the following questions:

15 (a) What studies and assessments have previously been performed that reviewed
16 transmission system vulnerabilities to geomagnetic and electromagnetic disturbances?

17 (b) How were those studies conducted and what were the transmission system grid
18 vulnerabilities identified?

19 (c) Given the current NERC GMD standard of 3 V/km and the IEC international
20 standard of 85 V/km, did the magnetic field standard utilized adequately assess the vulnerability of
21 the transmission system in New Hampshire to geomagnetic and electromagnetic disturbances?

22 (d) If the magnetic field standard utilized in previous studies did not adequately assess
23 transmission infrastructure vulnerability, what standard should be used?

24 (e) What would be the cost to conduct a transmission infrastructure assessment at a
25 higher standard than has previously been used?

26 (f) How long would an additional assessment at a higher standard take to complete?

27 (g) What mitigation strategies and response methods are currently utilized to protect
28 transmission system infrastructure from geomagnetic and electromagnetic disturbances and are
29 those strategies and methods adequate?

30 (h) What role can the state of New Hampshire play in assessing transmission system
31 vulnerabilities that fall under the jurisdiction of the Federal Energy Regulatory Commission and in
32 directing transmission-owning utilities to implement infrastructure and non-infrastructure
33 solutions?

34 (i) What funding sources are available to conduct additional assessments or support the
35 installation of equipment to further protect vulnerable transmission system infrastructure from
36 geomagnetic and electromagnetic disturbances?

Amendment to HB 1723

- Page 3 -

1 II. The department shall commence the investigation within 90 days of the effective date of
2 this subsection and complete the investigation within a time period not to exceed 12 months of its
3 commencement. At the conclusion of the investigation, the department shall issue a report of its
4 findings and recommendations to the house science, technology and energy committee, the senate
5 energy and natural resources committee, and the division of homeland security and emergency
6 management and the department shall also send the report to the United States Secretary of
7 Energy, the Federal Energy Regulatory Agency, and ISO-New England.

8 III. Notwithstanding any other law, rule, or order to the contrary, the department shall have
9 the authority necessary to conduct this investigation and implement this subdivision, including, but
10 not limited to, the authority to request information from public utilities, including transmission
11 utilities, regarding transmission infrastructure located within the state of New Hampshire, and to
12 specifically assess utilities an amount not to exceed \$350,000 for this investigation.

13 IV. Confidentiality. All data submitted under this subsection shall be handled in accordance
14 with critical energy infrastructure information protocols and location and purpose data shall be
15 redacted from public reports. "Critical energy infrastructure information protocols" means specific
16 engineering, vulnerability, or detailed design protocols and procedures related to proposed or
17 existing critical infrastructure, whether physical or virtual, that relate to the production, generation,
18 transmission, transportation, or distribution of energy, the unauthorized disclosure of which could
19 pose a risk to the security, reliability, or integrity of the infrastructure; such protocols are designated
20 as confidential and exempt from public disclosure, as their release could be useful to a person
21 planning an attack or otherwise causing harm to the infrastructure.

22 4 Effective Date. This act shall take effect upon its passage.

Amendment to HB 1723
- Page 4 -

2026-0935h

AMENDED ANALYSIS

This bill directs the Department of Energy to investigate vulnerabilities of electric transmission transformers to geomagnetic and electromagnetic disturbances and report findings with recommendations.